

Metal	Australian Drinking Water Health Guideline (2011) Values (mg/L)	Results of Hazelwood Water Testing (mg/L) 15/2/2014
Al	0.2 (aesthetic – taste)	<0.01 to <u>6.8</u>
Sb	0.003	<0.001
As	0.007	<0.001 to 0.002
Ba	0.7	<0.001 to 0.35
Be	0.06	<0.001
B	4	<0.02 to 0.22
Cd	0.002	<0.002
Cr	0.05 (as Cr VI)	<0.001 to 0.012
Co	NA	<0.001 to 0.005
Cu	2	<0.002 to 0.010
Fe	0.3 (Aesthetic – taste/odour)	<0.01 to <u>12</u>
Pb	0.01	<0.001 to 0.005
Mn	0.5	<0.001 to 0.077
Hg	0.001	<0.001
Mo	0.05	<0.001
Ni	0.02	<0.001 to 0.008
Se	0.01	<0.001 to 0.002
Ag	0.1	<0.001
Sr	NA	<0.001 to 0.57
Th	NA	<0.001
Sn	NA	<0.001
Ti	NA	<0.001 to 0.092
V	NA	<0.001 to 0.027
Zn	3 (aesthetics - taste)	<0.001 to 0.022